

NBS-E 1600/3L 1000A 3P



Specifikace

Kód ETI	004673161
Popis	NBS-E 1600/3L 1000A 3P
Jmenovitý proud (A)	1000
Počet pólů	3
Normy	60947
Typ připojení	přední připojení
Jmenovité impulsní výdržné napětí (kV)	8
Jmenovité pracovní napětí (V AC)	690
Jmenovité izolační napětí (V)	1000
Jmenovitá zkratová schopnost při 415V Icu/Ics (kA)	36
Tepelné nastavení	0,4-1
Magnetické nastavení	1,5-10xI _n
Nastavitelné nebo pevné	nastavitelný

[Online stránka produktu](#)

Další dokumentace

[3D model](#)[Návod](#)[Prohlášení CE](#)[Eplan file](#)

Mezinárodní klasifikace ETIM

Klasifikace	EC000228
Název třídy	Power circuit-breaker for trafo/generator/installation protection
Rated permanent current I _u	1000A
Rated voltage	415...690V
Rated short-circuit breaking capacity I _{cu} at 400 V, 50 Hz	36kA
Overload release current setting	400...1000A
Adjustment range short-term delayed short-circuit release	600...10000A
Integrated earth fault protection	
Type of electrical connection of main circuit	Screw connection
Device construction	Complete device in housing
Suitable for DIN rail (top hat rail) mounting	
DIN rail (top hat rail) mounting optional	
With switched-off indicator	1
With under voltage release	
Number of poles	3
Position of connection for main current circuit	Front side
Type of control element	Toggle
Complete device with protection unit	1
Motor drive integrated	
Motor drive optional	1
Degree of protection (IP)	IP20