

NBS-TMD 630/3L 500A 3P



Specifikace

Kód ETI	004673131
Popis	NBS-TMD 630/3L 500A 3P
Jmenovitý proud (A)	500A
Počet pólů	3
Skupina katalogu	NBS
Normy	60947
Typ připojení	přední připojení
Jmenovité impulsní výdržné napětí (kV)	8kV
Jmenovité pracovní napětí (V AC)	690V
Jmenovité izolační napětí (V)	1000V
Jmenovitá zkratová schopnost při 415V Icu/Ics (kA)	36kA
Tepelné nastavení	0,7-1
Magnetické nastavení	(5-10)In
Nastavitelné nebo pevné	nastavitelný

[Online stránka produktu](#)

Další dokumentace

[Katalog technických údajů](#)[3D model](#)[Návod](#)[Prohlášení CE](#)[Eplan file](#)

Mezinárodní klasifikace ETIM

Klasifikace	EC000228
Název třídy	Power circuit-breaker for trafo/generator/installation protection
Rated permanent current I _u	500A
Rated voltage	415...690V
Rated short-circuit breaking capacity I _{cu} at 400 V, 50 Hz	36kA
Overload release current setting	400...500A
Adjustment range undelayed short-circuit release	2500...5000A
Integrated earth fault protection	
Type of electrical connection of main circuit	Screw connection
Device construction	Complete device in housing
Suitable for DIN rail (top hat rail) mounting	
DIN rail (top hat rail) mounting optional	
With switched-off indicator	1
With under voltage release	
Number of poles	3
Position of connection for main current circuit	Front side
Type of control element	Toggle
Complete device with protection unit	1
Motor drive integrated	
Motor drive optional	1
Degree of protection (IP)	IP20